

School Name	Sample #	Sample Location	First Draw Lead Mg/L	First Draw Copper Mg/L	Flush Lead mg/l	Flush Copper mg/l
High School/Middle School						
	16-0655A-001/016	Kitchenette	0.023	0.044	0.0043	0.016
	16-0655A-007/003	Room 208	0.018	0.26	0.0056	0.054
	16-0655A-008/010	2nd Floor Faculty Lounge	0.02	1.3	0.0012	0.08
	16-0655A-011/009	Room 213	0.045	15	0.093	0.32
	16-0655A-018/017	GH Spigot	0.13	0.52	0.0026	0.15
	16-0655A-021/22	H.S. Nurse	<0.0010	0.25	0.042	0.85
	16-0655A-023/024	Room 185	0.0048	0.62	0.15	0.51
	16-0655A-025/026	Boys Locker Room	0.022	0.18	0.0057	0.11
	16-0655A-033/034	M.S. Nurse	0.016	0.54	0.0078	0.16
	16-0655A-036/035	1st Floor Faculty	0.039	1.3	<0.0010	0.25
	16-0655A-037/038	Faculty Mens	0.0026	0.059	0.033	0.2
	16-0655A-039/040	Stadium	0.019	0.25	0.018	0.26
Midland Elementary						
	16-0655B-003/004	Room 40	0.035	1.1	0.016	1.1
	16-0655B-005/006	Room 46	0.012	4.1	<0.0010	0.15
	16-0655B-007/008	Nurse	0.031	0.31	<0.0010	0.076
	16-0655B-009/010	Kitchenette	0.056	0.97	<0.0010	0.056
	16-0655B-011/012	Faculty Lounge	0.057	1.8	0.0064	0.14
	16-0655B-017/018	Special Ed Bath	0.89	5.2	<0.0010	0.22
Central Administration & Osborn						
	16-0655C-003/004	Kitchenette	0.015	0.19	0.0072	0.053
	16-0655C-011/012	Primary 3	0.21	0.33	0.013	0.1
	16-0655C-013/014	Room 22 Bubbler	0.015	0.48	0.0023	0.37
	16-0655C-015/016	Library Bubbler	0.0084	0.35	0.015	0.16
	16-0655C-017/018	Room 32 Bubbler	0.015	0.27	0.0039	0.21
Milton Elementary						
	16-0655D-008/007	Room B24	0.022	21	0.002	5.9
	16-0655D-015/016	Faculty Lounge	0.059	0.92	<0.0010	0.058